

TestAmerica Laboratories, Inc.

Eurofins TestAmerica, Edison

SUMMARY OF ANALYTICAL RESULTS: 460-209161-1

Job Description: Neighborhood House Association

For:

Neighborhood House Association - 644

644 West 4th Street

Plainfield, New Jersey 07060

Client ID	NJ Pri-Sec	644A			644B			644C			644D		
Lab Sample ID	Drinking Water	460-209161-1			460-209161-2			460-209161-3			460-209161-4		
Sampling Date	Standards	05/18/2020 10:33:00			05/18/2020 10:31:00			05/18/2020 10:30:00			05/18/2020 10:35:00		
Matrix	2018	Water			Water			Water			Water		
Unit		Result	Q	MDL	Result	Q	MDL	Result	Q	MDL	Result	Q	MDL
WATER BY 200.8(UG/L)													
Copper	1300	551		0.48	123		0.24	230		0.24	387		0.24
Lead	15	7.3		0.11	0.33	J	0.053	3.8		0.053	0.15	J	0.053

J : Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Lab Contact:

Jill Miller

Senior Project Manager

(484)685-0871